

Primary Health Centre
Mehakari,
Dist. - Ahmednagar.


HEALTH & SANITATION CERTIFICATE

This is to certify that, I have visited & done inspection at Takshila School, Jamkhed Road, Wadarwadi, Bhingar, Ahmednagar.

The School has maintained cleanliness and healthy environment, proper sanitation as per norms laid by Medical Officer, PHC Mehekari, Ahmednagar

Date : 07 / 03 / 2024

Place : Ahmednagar


वैद्यकिय अधिकारी
प्राथमिक आरोग्य केंद्र
मेहेकरी, ता.जि. अहमदनगर

महाराष्ट्र राज्य सार्वजनिक आरोग्य सेवा

राज्य/प्रादेशिक/जिल्हा आरोग्य प्रयोगशाळा, अहमदनगर दूरध्वनी क्रमांक

पाणी नमुन्याचा सूक्ष्मजीवीय अहवाल

प्रति, :- तक्षिला स्कूल, अहमदनगर
 पाठविणान्यांचे पत्र क्रमांक व दिनांक :- ०१/३/२४ (जामखेड रोड).
 प्रयोगशाळा संदर्भ क्रमांक :- २०१५८
 नमुना घेतल्याचा दिनांक :- ०१/३/२०२४
 नमुना पोहचल्याचा दिनांक :- ०१/३/२०२४
 परीक्षण सुरु केल्याचा दिनांक :- ०१/३/२०२४

अ. क्र.	नमुन्याचे विवरण	परीक्षणाचे निष्कर्ष			इतर अभिप्राय
		प्रती १०० मि.ली. नमुन्यातील संभाव्य सूक्ष्मजंतूची संख्या			
		कोलीफॉर्मस	थर्मोटॉलरंट कोलीफॉर्मस	इ. कोलाय	
	<u>आर, पाणी नमुना तक्षिला स्कूल अहमदनगर</u>	<u>००</u>	<u>-</u>	<u>-</u>	<u>पिण्यायोग्य</u>

अभिप्राय : पिण्यास अयोग्य पाण्यावर योग्य प्रमाणात क्लोरिनची प्रक्रिया केल्यानंतर व सूक्ष्मजीवीय पुर्वतपासणीनंतर पिण्यास योग्य असल्याची खात्री झाल्यानंतर ते पाणी पिण्यासाठी वापरता येईल.

अहवाल क्रमांक : ५१०

अभिप्राय तारेने कळविल्याचा दिनांक :

प्रत सादर :

- (१) जिल्हा आरोग्य अधिकारी, जिल्हा परिषद, जिल्हा
- (२) शल्यचिकित्सक, जिल्हा रुग्णालय, जिल्हा
- (३) तालुका आरोग्य अधिकारी पंचायत समिती



दिनांक :- ०२/३/२०२४

कनिष्ठ वैज्ञानिक अधिकारी
 जिल्हा आरोग्य प्रयोग शाळा
 अहमदनगर-४१४ ००१.

State / Regional / District / Public Health Laboratory AhmadnagarE-mail-ID : dphloms@gmail.com

Phone No. :

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection :— 07.03.24 Date of Receipt :— 07.03.24 Date of Examination :— 07.03.24
(All the Analytical Results are in mg./Litre except pH, Turbidity) onwards

Sr. No.	TEST PARAMETER	(1) JAR water	(2)	(3)	BIS Specification 10500 : 2012 Normal Values	
					Desirable Limits	Permissible Limits
1.	Physical Appearance	clear			—	—
2.	Odour	Odourless			Agreeable	Agreeable
3.	Turbidity (as N.T.U.)	0.50			1.0	5.0
4.	pH Value	<u>6.2</u>			6.5 to 8.5	No relaxation
5.	Chlorides (as Cl)	24			250	1000
6.	Nitrates (as NO ₃)	1.12			45	No relaxation
7.	Total Hardness (as CaCO ₃)	28			200	600
8.	Alkalinity (as CaCO ₃)	50			200	600
9.	Total Dissolved Solids	90			500	2000
10.	Iron (as Fe)	0.08			0.3	No relaxation
11.	Fluoride (as F)	0.12			1.0	1.5
12.	Other Tests (if any)	—				
13.						
14.						
15.						
16.						
17.						
18.						
19.						
20.						

- This report is restricted only for the Sample/s is Submitted to this Laboratory.
- This Sample/s is / are not Collected by this Laboratory.

[P.T.O.]

REMARKS

A) Sample No. (s) _____ is/are potable / chemically fit for drinking purpose on the basis of analysed parameters only.

However, this / these water source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

B) Sample No. (s) 01 Contains pH value less than limit (6.5 to 8.5)

However, if there is no any other alternate source available nearby then this / these water Source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

C) Sample No. (s) _____ Contains _____

Hence, this / these water Source/s is / are chemically non-potable / unfit for drinking purpose on the basis of analysed parameters only.

HEALTH SERVICES

No. 599/24

Date :- 12-3-24

Forwarded With Compliments To :

साहिबा स्कूल

जामखेड रोड, अहमदनगर

With reference to letter No. : _____

Dated :- 07/03/24

Fees Rs. : 940/-

Receipt No. and Date : 4461291/07.03.24

B. B. B.
 Junior Scientific Officer
 District Public Health Laboratory
 Ahmednagar